

ATTACHMENT 6


Consumer Confidence Report Certification Form (to be submitted with a copy of the CCR)

Water System Name: Fountain Trailer Park Water

Water System Number: 1500461

The water system named above hereby certifies that its Consumer Confidence Report was distributed on 7/1/2018 (date) to customers (and appropriate notices of availability have been given). Further, the system certifies that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the Department of Public Health.

Certified by: Name: Mario Cervantes

Signature: 

Title: Operator

Phone Number: (661) 805-7648

Date: 6/27/2018

To summarize report delivery used and good-faith efforts taken, please complete the below by checking all items that apply and fill-in where appropriate:

☒ CCR was distributed by mail or other direct delivery methods. Specify other direct delivery methods used: Hand delivery & Mail.

☐ "Good faith" efforts were used to reach non-bill paying consumers. Those efforts included the following methods:

☐ Posting the CCR on the Internet at www.

☐ Mailing the CCR to postal patrons within the service area (attach zip codes used)

☐ Advertising the availability of the CCR in news media (attach copy of press release)

☐ Publication of the CCR in a local newspaper of general circulation (attach a copy of the published notice, including name of newspaper and date published)

☐ Posted the CCR in public places (attach a list of locations)

☐ Delivery of multiple copies of CCR to single-billed addresses serving several persons, such as apartments, businesses, and schools

☐ Delivery to community organizations (attach a list of organizations)

☐ For systems serving at least 100,000 persons: Posted CCR on a publicly-accessible internet site at the following address: www.

☐ For privately-owned utilities: Delivered the CCR to the California Public Utilities Commission

2017 Consumer Confidence Report

Water System Name: Fountain Trailer Park

Report Date: June 2018

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2017 and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: Ground water

Name & general location of source(s): Well #01

Drinking Water Source Assessment information: Water assessment maybe viewed at the water office

Time and place of regularly scheduled board meetings for public participation: _____

For more information, contact: Mario Cervantes, System Operator

Phone: (661) 805-7648

TERMS USED IN THIS REPORT

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs for contaminants that affect health

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Variances and Exemptions: State Board permission to exceed an MCL or not comply with a treatment technique under certain conditions.

Level 1 Assessment: A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (µg/L)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picogram per liter (pg/L)

along with their monitoring and reporting **pCi/L**: picocuries per liter (a measure of radiation) requirements, and water treatment requirements.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, that can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the USEPA and the State Water Resources Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

Tables 1, 2, 3, 4, 5, and 6 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old. Any violation of an AL, MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

TABLE 1 – SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (complete if bacteria detected)	Highest No. of Detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria (state Total Coliform Rule)	(In a mo.) 0	0	1 positive monthly sample	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i> (state Total Coliform Rule)	(In the year) 0	0	A routine sample and a repeat sample are total coliform positive, and one of these is also fecal coliform or <i>E. coli</i> positive		Human and animal fecal waste
<i>E. coli</i> (federal Revised Total Coliform Rule)	0		(a)	0	Human and animal fecal waste

(a) Routine and repeat samples are total coliform-positive and either is *E. coli*-positive or system fails to take repeat samples following *E. coli*-positive routine sample or system fails to analyze total coliform-positive repeat sample for *E. coli*.

TABLE 2 – SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (complete if lead or copper detected in the last sample set)	Sample Date	No. of sample s collected	90 th percentile level detected	No. sites exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)					15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits

Copper (ppm)					1.3	0.3	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
--------------	--	--	--	--	-----	-----	---

TABLE 3 – SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	2015	110	76-210	none	none	Salt present in the water and is generally naturally occurring
Hardness (ppm)	2015	38	65-370	none	none	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

TABLE 4 – DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Arsenic (ppb)*	12-26-17	91	15-19	10	.004	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes
Aluminum (ppb)	12-26-15	<.05	.11-.21	2	1	Erosion of natural deposits; residue from some surface water treatment processes
Antimony (ppb)	12-26-15	<.02	<2	50	30	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder
Asbestos	12-26-15	<.01	4-20	10	1	
Barium (ppb)	12-26-15	12	0-25	1000	0.43	Discharge of oil drilling wastes and from metal refineries; erosion of natural deposits
Beryllium (ppb)	12-26-15	<.01	1000	2000		Discharge from metal refineries; coalburning factories, electrical, aerospace, defense industries.
Cadmium (ppb)	12-26-15	<1	4	1		Internal corrosion of galvanized pipes; erosion of natural deposits; discharge from electroplating and industrial chemical factories and metal refineries; runoff from waste batteries and paints
Chromium (ppb)	12-26-15	13	4	0.07		Discharge from steel and pulp mills and chrome plating; erosion of natural deposits
Fluoride (ppm)	12-26-15	1.1	50	N/A		Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Mercury (ppb)	12-26-15	<.20	2	1		Erosion of natural deposits; discharge from refineries and factories; runoff from landfills runoff from cropland
Nickel (ppb)	12-26-15	<.1	2	1.2		Erosion of natural deposits; discharge from metal factories
Nitrate (as N) (ppm)	12-26-17	.4	100	12		Runoff and leaching from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Perchlorate (ppb)	12-26-15	<0.04	<4	6	6	Perchlorate is an inorganic chemical used in solid rocket propellant, fireworks, explosives, flares, matches, and a variety of industries. It usually gets into drinking water as a result of environmental

Selenium (ppb)	12-26-15	<2	<2	50	N/A	Discharge from petroleum, glass and metal refineries; erosion of natural deposits; discharge from mines and chemical manufacturers; runoff from livestock lots (feed additive)
Thallium (ppb)		<1	<1	2	0.1	Leaching from ore-processing sites; discharge from electronics, glass and drug factories

TABLE 5 – DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Copper (ppm)	12-26-2015	<.01	<10.	1	N/A	Internal corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Foaming Agents (MBAS) (ppb)	12-26-2015	<.01	<.200	500	None	Leaching from natural deposits; industrial wastes
Hardness (Total) as CaCO ₃	12-26-2015	38	120-130	None	None	
Hydroxide Alkalinity (ppm)	12-26-2015	<1.4				
Iron (ppb)	12-26-2015	79				Leaching from natural deposits; industrial wastes
Manganese (ppb)	12-26-2015	<.01	<.810	None		Leaching from natural deposits.
Magnesium (ppm)	12-26-2015	2.7	<50-540	300	None	Erosion of natural deposits
Odor (Units)	12-26-2015	ND	<10.-22	50	None	Naturally - occurring organic materials
PH, Laboratory	12-26-2015	8.2	5.6-6.2			Inherent characteristic of water
Silver (ppb)	12-26-2015	<.01	ND	3 Units	None	Industrial discharges
Sodium (ppm)	12-26-2015	110	8.04-8.23	None	None	Generally found in ground and surface water
Specific Conductance (EC)	12-26-2015	529	<10	100	N/A	Substances that form ions when in water; Seawater influence
Sulfate (ppm)	12-26-2015	64	42-48	None	None	Runoff/leaching from natural deposits; industrial wastes
Total Dissolved Solids (TDS) (ppm)	12-26-2015	360	409-419	1600	N/A	Runoff/leaching from Natural deposits
Turbidity (NTU)	12-26-2015	0.8	57-60	500	None	Soil runoff
Zinc (ppb)	12-26-2016	<.5	<50-67	5000	(5)	Runoff/leaching from natural deposits; industrial wastes

TABLE 6 – DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
N/A					

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Lead-Specific Language for Community Water Systems: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [Fountain Trailer Park.] is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. [Optional: If you do so, you may wish to collect the flushed water and reuse it for another beneficial purpose, such as watering plants.] If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4701) or at <http://www.epa.gov/lead>.

Summary Information for Violation of a MCL, MRDL, AL, TT, or Monitoring and Reporting Requirement

VIOLATION OF A MCL, MRDL, AL, TT, OR MONITORING AND REPORTING REQUIREMENT				
Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
Arsenic	Erosion of natural deposits; runoff from orchards; glass and electronics production wastes	2009-present	A grant is currently being processed to possibly find a new well with low levels of Arsenic	Your drinking water exceeds the current standard for Arsenic. The standard balances the current understanding of Arsenic's possible health effects against the costs of removing Arsenic from drinking water. The California Department of Health Services continues to

				research the health effects of low levels of Arsenic.

For Water Systems Providing Ground Water as a Source of Drinking Water

**TABLE 7 – SAMPLING RESULTS SHOWING
FECAL INDICATOR-POSITIVE GROUND WATER SOURCE SAMPLES**

Microbiological Contaminants (complete if fecal-indicator detected)	Total No. of Detections	Sample Dates	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
<i>E. coli</i>	(In the year) 0	N/A	0	(0)	Human and animal fecal waste
Enterococci	(In the year) 0	N/A	TT	n/a	Human and animal fecal waste
Coliphage	(In the year) 0	N/A	TT	n/a	Human and animal fecal waste

Summary Information for Fecal Indicator-Positive Ground Water Source Samples, Uncorrected Significant Deficiencies, or Ground Water TT

SPECIAL NOTICE OF FECAL INDICATOR-POSITIVE GROUND WATER SOURCE SAMPLE

SPECIAL NOTICE FOR UNCORRECTED SIGNIFICANT DEFICIENCIES

Fluoride: Some people who use water containing fluoride more than the Federal MCL of 4ppm, over many years may get bone disease, including pain and tenderness of the bone. Children who drink water containing fluoride more than state MCL of 2ppm may get mottled teeth.

VIOLATION OF GROUND WATER TT

TT Violation	Explanation	Duration	Actions Taken to Correct the Violation	Health Effects Language
None				

this occurs, we are required to conduct assessment(s) to identify problems and to correct any problems that were found during these assessments.

Fountain Trailer Park

IMPORTANT

2017 Consumer Confidence Report

Este informe contiene informacion muy importante sobre su agua beber. Traduzcalo o hable con alguien que lo entienda bien.